

21 March 1960

SUBJECT : Test/Operational Site Requirements

(Minneapolis-Honeywell Regulator Company)

1. [redacted] of Minneapolis-Honolulu Regulator Company submitted the following requirement for space [redacted]

25X1

a. 500 sq. ft. of shop/office space adjoining

b. Power requirements:

(1) 115 Volt AC, 400 cycle, single phase 850 volt ampha.

(2) 28 Volt± DC, 10 amps.

(3) 115 Volt AC, 60 cycle, single phase, 2,000 volt amps.

25X1

SIGNED

38

☒

2012

7

100

1

25X1